

Bidders

May 13, 2022
File No. 222-0163

Subject: **Clovis Unified School District
Portable Classroom Improvements
Various Sites
Addendum 2**

Bidders,

The following items are descriptions of the changes to the Construction Documents for the Portable Classroom Improvements at Various Sites project.

SPECIFICATIONS

The specifications have been approved by DSA and are being issued with this addendum.

CLOVIS ONLINE CHARTER

The plans have been approved by DSA and are being issued with this addendum. The changes are detailed below but are not clouded on the plans so that there is a clean set of DSA plans.

Plans

1. Sheet C100L – Cover Sheet

- a. Revision of Governing Codes.
- b. Revision of Sheet Index.

2. Sheet C101L – Accessibility Plan

- a. Addition of notes 2-5 on Project Data / Code Analysis, Occupant Load Calculation.

3. Sheet X101L – Details

- a. Revision to Detail B/X101L.

4. Sheet E201 – Fire Alarm Notes & Details

- a. Addition of Annunciate Supervisory to Action for Smoke, Heat Detector initiation Condition on detail 2, Fire Alarm Sequence of Operation Matrix.

FUGMAN ELEMENTARY SCHOOL

The plans have been approved by DSA and are being issued with this addendum. The changes are detailed below but are not clouded on the plans so that there is a clean set of DSA plans.

Plans

1. Sheet C100F – Cover Sheet

- a. Revision of Governing Codes.
- b. Revision of Sheet Index.

2. Sheet X101F – Details

- a. Revision to Detail B/X101F.

3. Sheet E201 – Fire Alarm Notes & Details

- a. Addition of Annunciate Supervisory to Action for Smoke, Heat Detector initiation Condition on detail 2, Fire Alarm Sequence of Operation Matrix.

VIRGINIA R. BORIS ELEMENTARY SCHOOL

The plans have not been approved by DSA yet. but the changes to the Plans are detailed below. Once approved by DSA, a new plan set will be issued.

Plans

1. Sheet C100B – Cover Sheet

- a. Revision of Governing Codes, same as to the plans for Clovis OnLine and Fugman, see attached sheet A2-1.
- b. Revision of Sheet Index, see attached sheet A2-2.

2. Sheet C301B – Site Plan

- a. Revision on note 2, Site Legend, see attached sheet A2-3.

3. Sheet E201 – Fire Alarm Notes & Details

- a. Addition of Annunciate Supervisory to Action for Smoke, Heat Detector initiation Condition on detail 2, Fire Alarm Sequence of Operation Matrix, see attached sheet A2-4.

Best regards,

BLAIR, CHURCH & FLYNN CONSULTING ENGINEERS

A handwritten signature in black ink, appearing to read "Lane R. Bader". The signature is fluid and cursive, with a large loop at the end.

Lane R. Bader, PE
Project Manager



SHEET A2-1

GOVERNING CODES:

2022 CALIFORNIA ADMINISTRATIVE CODE (CAC), C.C.R. TITLE 24, PART 1
2019 CALIFORNIA BUILDING CODE (CBC), C.C.R. TITLE 24, PART 2
2019 CALIFORNIA ELECTRICAL CODE (CEC), C.C.R. TITLE 24, PART 3
2019 CALIFORNIA MECHANICAL CODE (CMC), C.C.R. TITLE 24, PART 4
2019 CALIFORNIA PLUMBING CODE (CPC), C.C.R. TITLE 24, PART 5
2019 CALIFORNIA FIRE CODE (CFC), C.C.R. TITLE 24, PART 9
2019 CALIFORNIA REFERENCED STANDARDS CODE C.C.R. TITLE 24, PART 12
2019 CALIFORNIA ENERGY CODE (CAC), C.C.R. TITLE 24, PART 6

SHEET A2-2

<i>RELOCATABLE BUILDING PC 04-119396</i>	
<i>F1</i>	<i>COVER SHEET</i>
<i>F2</i>	<i>A-NUMBERS</i>
<i>F3</i>	<i>FOUNDATION PLANS</i>
<i>F3A</i>	<i>FOUNDATION PLANS</i>
<i>F3B</i>	<i>FOUNDATION PLANS</i>
<i>F3C</i>	<i>FOUNDATION PLANS</i>
<i>F4</i>	<i>FOUNDATION PLANS</i>
<i>F4A</i>	<i>FOUNDATION PLANS</i>
<i>F4B</i>	<i>FOUNDATION PLANS</i>
<i>F4C</i>	<i>FOUNDATION PLANS</i>
<i>F5</i>	<i>FOUNDATION PLANS</i>
<i>F5A</i>	<i>FOUNDATION PLANS</i>
<i>F5B</i>	<i>FOUNDATION PLANS</i>
<i>F5C</i>	<i>FOUNDATION PLANS</i>
<i>F6</i>	<i>DETAILS</i>
<i>F7</i>	<i>GENERAL SPECIFICATIONS</i>
<i>F7A</i>	<i>DSA FORM 103</i>
<i>F8</i>	<i>ADJACENT BUILDINGS DETAILS</i>
<i>F9</i>	<i>ADJACENT BUILDINGS DETAILS</i>

SHEET A2-3

2

*WELD 6"X6"X1/4" GALV. PLATE TO BOTTOM OF FENCE
POST AND MOUNT ON VALLEY GUTTER USING FOUR (4)
1/4"X3" HILTI KWIK BOLT TZ2 WEDGE ANCHORS OR
APPROVED EQUAL PER DETAIL [A/X101B]*

SHEET A2-4

INITIATION CONDITON	SMOKE, HEAT DETECTOR	POWER LOSS, SHORT CIRCUIT, GROUND FAULT
ACTION		
ANNUNCIATE TROUBLE		●
ANNUNCIATE ALARM	●	
ANNUNCIATE SUPERVISORY	●	
INITIATE NOTIFICATION APPLICANCES	●	
INITIATE EV/AC APPLICANCES	●	
TRANSMIT TO CENTRAL STATION	●	●

FIRE ALARM SEQUENCE OF OPERATION MATRIX

NO SCALE

2