

March 10, 2023

**CLOVIS UNIFIED SCHOOL DISTRICT
BID 2926 PAINTING AT VARIOUS SITES**

ADDENDUM NO. 3

This addendum forms a part of the bid/contract documents. It modifies the original project plans, specifications, and instructions. Bidders are required to acknowledge receipt of this addendum on the sheet included with the bid package. Failure to acknowledge receipt of this addendum may subject the bidder to disqualification.

MAP REVISION AND CLARIFICATION:

The map attached is adjusted to add a building.

- Use extreme bond primer on stucco of building number 3.
- Louvers on energy building in section number 2 are painted. The metal roof above louvers is prefinished metal and not painted.
- Add building in section number 1 per map attached.


If you have any questions, please feel free to contact my office at 559-327-9482.



Tracy Ogle
Buyer II

2-page addendum

- KEYNOTES**
- ① DM18
 - ② 3501-17/15
 - ③ DM18
 - ④ 20-339-1/2
 - ⑤ STEEL GARD
 - ⑥ 0360/8
 - ⑦ 5617/6
 - ⑧ NOT USED
 - ⑨ DM18
 - ⑩ 20-10-1/2
 - ⑪ NOT USED
 - ⑫ STEEL GARD
 - ⑬ 4186/85



Buckman High School - partial site
 1860 N. Minnesota, Clovis California 93212