

**October 03, 2022**

**CLOVIS UNIFIED SCHOOL DISTRICT  
BID 2912 – ENERGY MANAGEMENT SYSTEM UPGRADE – VARIOUS SITES**

**ADDENDUM NO. 2**

This addendum forms a part of the bid/contract documents. It modifies the original project plans, specifications and instructions. Bidders are required to acknowledge receipt of this addendum on the sheet included with the bid package. Failure to acknowledge receipt of this addendum may subject the bidder to disqualification.

**Revisions:**

This project will proceed in phases (Aggregates 1-3) with start dates at the direction of CUSD.

Aggregate 1 (180 days)

Aggregate 2 (150 days),

Aggregate 3 (180 days)

**Clarification:**

- 1) Each JACE (R2 or AX) listed on this project must be replaced by a new N4 JACE. N4 JACEs that are currently operating on the site and not part of this project scope cannot be used as part of this project.
- 2) Bid bond must be based on the total bid amount.

If you have any questions, please feel free to contact my office at 559-327-9479.

Leeann Errotabere  
Director of Purchasing

1-page addendum