

## ADDENDUM NO. 2

Project: **REROOF OF COLE ELEMENTARY SCHOOL  
CLOVIS UNIFIED SCHOOL DISTRICT  
615 W. STUART AVENUE  
CLOVIS, CALIFORNIA**

To all bidders submitting proposals for the above cited project, items covered in this addendum as hereby made part of the contract documents to the same extent as though it were originally contained therein.

**ITEM NO. 01**                    **PROJECT SPECIFICATIONS – SECTION 07 22 00 (Insulation) – Part 2 –  
Section 2.01& 2.02 & Section 3.03 (Insulation Installation)**

**Omit:** All references to installation of polyisocyanurate roof insulation as part of low-slope roofing system.

**ITEM NO. 02**                    **PROJECT SPECIFICATIONS - SECTION 07 31 11 (Reflective Laminated Asphalt  
Shingle Roofing) – Section 1.02 – Section A, (Description of Work)**

**Add:** New low-profile roof vents are to be installed at all shingle roof areas at rate of one (1) vent per four hundred (400) square feet of roof surface, excluding overhang areas.

**ITEM NO. 03**                    **Technical Specifications – Section 07 31 11(Reflective Laminated Asphalt Shingle  
Roofing) - Part 3.03, Section C**

**Omit:** Reference to installation of one (1) layer of synthetic shingle underlayment at all shingle roof areas.

**Add:** Install two (2) layers of approved synthetic shingle underlayment at all roof areas which have a designed slope of less than four (4) inches in 12". Areas having a designed slope exceeding four (4) inches per foot may be reduced to one (1) layer of approved underlayment.

**ITEM NO. 04**                    **Technical Specifications – Section 07 31 11 (Reflective Laminated Asphalt  
Shingle Roofing) – Section 2.02 Materials**

**Omit:** The following minimum requirements:

Shingle Initial Reflectivity of .26  
Shingle Initial Emissivity of .92  
Shingle Aged Reflectivity of .25

**Add:** The following minimum requirements

Shingle Initial Reflectivity of .19  
Shingle Initial Emissivity of .91  
Shingle Aged Reflectivity of .20