

## ADDENDUM

PROJECT: Clovis West High School – Ceramics Classroom

ADDRESS: 1070 E. Teague

Fresno, CA 93720

OWNER: Clovis Unified School District

1450 Herndon Ave. Clovis, CA 93611

ADDENDUM#: **01** 

DATE: 6/08/2023

PHA JOB NO.: 2023-06

The following additions, deletions and revisions to the plans, specifications and addenda shall become a part of the Contract Documents. It is the responsibility of the Construction Manager to submit the information contained in this addendum to all bidders. Each bidder shall acknowledge receipt of this Addendum in their respective Bid Proposals. (Addendum number of pages: **01** pages and **00** attachments = **01** total pages.)

## **PROJECT MANUAL**

## Item 01-01

Reference: E100 – ELECTRICAL REFLECTED CEILING PLAN,

a. Refer to Sheet E100, replace Keynote #2 with the attached following language.

## KEYNOTES ()

 EXISTING PANEL TO REMAIN. PROVIDE UPDATED TYPE-WRITTEN PANEL SCHEDULE IN ANY PANEL WHERE WORK IS PERFORMED. PANEL SCHEDULE SHALL BEAR THE NAME OF THE CONTRACTOR, THE DATE THE SCHEDULE WAS UPDATED, FACILITY NAME ("CLOVIS WEST"), BUILDING NAME ("C"), PANEL DESIGNATION (NAME), VOLTAGE, PHASE, NUMBER OF CIRCUITS.



- PROVIDE NEW GFCI-PROTECTED RECEPTACLE AT CEILING FOR CORD REEL. PROVIDE VIVO #MOUNT-VP07DP 2'X2' MOUNTING PLATE. PROVIDE 20A, 120V, GFCI-PROTECTED, TAMPER RESISTANT RECEPTACLE. R ATTACH MOUNT TO T-BAR GRID AND PROIDE SEISMIC BRACING PER ARCHITECTURAL REQUIREMENTS. PROVIDE AND INSTALL CORD REEL (HUBBELL #HBL125123GF20) TO MOUNTING PLATE WITH 1/4"-20X1-1/2" HHB, WASHER, LOCK WASHER AND HEX NUT. ATTACH MOUNTING PLATE TO T-BAR RUNNER WITH #10 SMS AT EACH SIDE.
- PROVIDE AND INSTALL NEW 30 CIRCUIT, 100A, 120/208V, 3Ø, 4W, NEMA 1, 10KAIC PANELBOARD 'CD4' PER PANEL SCHEDULE 'CD4'. SEE SINGLE LINE DIAGRAM FOR FEEDER INFORMATION. SEE DETAIL 2/E010.

**END OF ADDENDUM #01** 

T: 559.297.7900 F: 559.297.7950

389 Clovis Ave., Suite 100 Clovis, California 93612

www.halajianarch.com